Evidence of Performance

Air permeability, Watertightness, Resistance to wind load

Test Report No. 13-000237-PR03 (PB-A01-02-en-02)



Client Selectron Elektrokimya San.

ve Tic. Ltd. Sti.

Atatürk Bulvari Köstemir

yolu No:74

34570 Silivri - Istanbul

Turkey

Product Tilt and turn window

Designation System designation: FLAT 68f

Performance-relevant

product details

Overall dimensions

 $(W \times H)$

Special features

Material: Wood-Aluminium

1,230 mm x 1,480 mm

Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E1350

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C4 / B4

ift Rosenheim 12.04.2013

Robert Kolacny, Dipl.-Ing. (FH) Deputy Head of Testing Department **Building Components**

Stephan Rauscher, B.Eng. **Operating Testing Officer** Tightness & Wind Load

Basis

EN 14351-1:2006+A1:2010

Test standard/s: EN 1026:2000-06 EN 1027:2000-06 EN 12046-1:2003-11 EN 12211:2000-06 EN 14609:2004-06 Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 18 pages.



ift Rosenheim GmbH Geschäftsführer: Dr. Jochen Peichl Prof. Ulrich Sieberath Dr. Martin H. Spitzner Theodor-Gietl-Str. 7 - 9 D-83026 Rosenheim

Tel.: +49 (0)8031/261-0 Fax: +49 (0)8031/261-290 www.ift-rosenheim.de

Sitz: 83026 Rosenheim AG Traunstein, HRB 14763

Sparkasse Rosenheim Kto. 3822 BLZ 711 500 00

otified Body Nr.: 0757 nerkannte PÜZ-Stelle: BAY 18

