

Classification Report

Number	20-003330-PR01 (NW-A01-02-en-01)
Owner	Selectron Elektrokimya San. ve Tic. Ltd. Sti. Atatürk Bulvarı Köstemir yolu No:74 34570 Silivri - Istanbul Turkey
Product	Horizontally pivoting window
Designation	System: 78a Shipping name: Arbor –Fenex 78a Top Swing Window
Details	Manufacturer Selectron Elektrokimya San., ve Tic. Ltd. Sti. - Silivri - Istanbul; Material Wood-aluminium; Type of opening Hori- zontal pivot casement; Opening direction Outwards; Overall dimen- sions (W x H) 890 mm x 1480 mm
Special features	Test sequence. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-003330-PR01 PB-
A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

17.09.2020



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 9A9-B68AF